## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

## FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

**LISTING No.** 7271-1394:110 Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: \*Apollo Fire Detectors Ltd, 36 Brookside Road, Havant, Hampshire, P09 1JR, England

\*Contact: Gordon Ash +44(0)23 9249 2412 FAX +44(0)23 9249 2754

**DESIGN**: \*Series 65A Model 55000-225, -226, and -227 ionization smoke detectors. Model 55000-

226 is identical to Model 55000-227 except for the addition of an LED, which flashes in the quiescent state. Model 55000-225 includes both the LED and a magnet operated test

switch. Refer to listee's data sheet for detailed product description and operational

considerations.

**RATING**: \*Electrical: 9 to 33 VDC

**INSTALLATION**: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

**MARKING**: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as ionization smoke detectors for use with listee's separately listed compatible fire

alarm control units and listed Series 65A Models 45681 Series detector bases (CSFM Listing No. 7300-1394:109) and \*Series 60A Models 45681-200, -220, -232 and -251 bases (CSFM Listing No. 7300-1394:106). Refer to listee's Installation Instruction Manual for details.

**NOTE**: \*The ionization type detectors are generally more effective at detecting fast, flaming fires

which consume combustible materials rapidly and spread quickly. Sources of these fires may include paper burning in a waste container or a grease fire in the kitchen. The photoelectric type detectors are generally more effective at detecting slow, smoldering fires that smolder for hours before bursting into flames. Sources of these fires may include cigarettes burning in

couches or bedding.

\*Rev. 06-20-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 22, 2004 Listing Expires June 30, 2005

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager